



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Joseph Sbarra
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005**

10/6/2016

Phone: (212) 612-7900

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 9/30/2016. The results are tabulated on the attached data pages for the following client designated project:

**Peekskill Schools Lead Testing / 2041420.027.00 / Oakside
Elementary School**

The reference number for these samples is EMSL Order #011606397. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description OES-01
LS MENS RM
Collected: 9/29/2016
Lab ID: 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.36	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-02
L F RM#113
Collected: 9/29/2016
Lab ID: 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-03
L S RM#113 L
Collected: 9/29/2016
Lab ID: 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.71	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-04
L S RM#113 R
Collected: 9/29/2016
Lab ID: 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.61	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-05
L F RM #112
Collected: 9/29/2016
Lab ID: 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.08	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-06
L S RM #112 L
Collected: 9/29/2016
Lab ID: 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.50	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-07
L S RM #112 R
Collected: 9/29/2016
Lab ID: 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.5	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description OES-08
L F RM#101
Collected: 9/29/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-09
L S RM#101 L
Collected: 9/29/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.42	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-10
L S RM#101 R
Collected: 9/29/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.09	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-11
L F RM#111
Collected: 9/29/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-12
L S RM#111 L
Collected: 9/29/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-13
L S RM#111 R
Collected: 9/29/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.59	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-14
L F RM#102
Collected: 9/29/2016 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description OES-15
L S RM#102 L **Collected:** 9/29/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.74	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-16
L S RM#102 R **Collected:** 9/29/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.64	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-17
L F RM#110 **Collected:** 9/29/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-18
L S RM#110 L **Collected:** 9/29/2016 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.2	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-19
L S RM#110 R **Collected:** 9/29/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.23	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-20
L S RM#103 L **Collected:** 9/29/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.70	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-21
L S RM#103 R **Collected:** 9/29/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.9	1.00	µg/L	10/3/2016	LY	10/4/2016	KB

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
Fax:
Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description OES-22
L F RM#109 **Collected:** 9/29/2016 **Lab ID:** 0022

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-23
L S RM#109 **Collected:** 9/29/2016 **Lab ID:** 0023

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.31	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-24
L S RM#109 **Collected:** 9/29/2016 **Lab ID:** 0024

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.69	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-25
L F RM#104 **Collected:** 9/29/2016 **Lab ID:** 0025

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-26
L S RM#104 L **Collected:** 9/29/2016 **Lab ID:** 0026

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.0	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-27
L S RM#104 R **Collected:** 9/29/2016 **Lab ID:** 0027

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.67	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-28
L S WOMENS RM **Collected:** 9/29/2016 **Lab ID:** 0028

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	51.2	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
Fax:
Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description OES-29
L S REST RM **Collected:** 9/29/2016 **Lab ID:** 0029

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-30
L S RM#106 L **Collected:** 9/29/2016 **Lab ID:** 0030

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.04	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-31
L S RM#106 R **Collected:** 9/29/2016 **Lab ID:** 0031

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.99	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-32
L F RM#105 **Collected:** 9/29/2016 **Lab ID:** 0032

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.37	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-33
L S RM#105 L **Collected:** 9/29/2016 **Lab ID:** 0033

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.6	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-34
L S RM#105 R **Collected:** 9/29/2016 **Lab ID:** 0034

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.43	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-35
M S RM#212 BATHROOM **Collected:** 9/29/2016 **Lab ID:** 0035

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.86	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description OES-36
M S RM#212
Collected: 9/29/2016
Lab ID: 0036

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.69	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-37
M S GIRLS RM L
Collected: 9/29/2016
Lab ID: 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.02	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-38
M S GIRLS RM LC
Collected: 9/29/2016
Lab ID: 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.98	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-39
M S GIRLS RM RC
Collected: 9/29/2016
Lab ID: 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.19	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-40
M S GIRLS RM R
Collected: 9/29/2016
Lab ID: 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.73	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-41
M S REST RM
Collected: 9/29/2016
Lab ID: 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.57	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-42
M S RM#211
Collected: 9/29/2016
Lab ID: 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.22	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description OES-43
M F RM#201
Collected: 9/29/2016 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.81	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-44
M S RM#201
Collected: 9/29/2016 **Lab ID:** 0044

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.1	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-45
M F RM#210
Collected: 9/29/2016 **Lab ID:** 0045

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.41	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-46
M S RM#210
Collected: 9/29/2016 **Lab ID:** 0046

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.29	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-47
M F RM#202
Collected: 9/29/2016 **Lab ID:** 0047

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.14	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-48
M S RM#202
Collected: 9/29/2016 **Lab ID:** 0048

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.40	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-49
M S RM#209
Collected: 9/29/2016 **Lab ID:** 0049

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.11	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description		OES-50 M F RM#203	Collected:		9/29/2016	Lab ID:	0050	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	5.48	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-51 M S RM#203	Collected:		9/29/2016	Lab ID:	0051	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.29	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-52 M S RM#208	Collected:		9/29/2016	Lab ID:	0052	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.45	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-53 M F RM#204	Collected:		9/29/2016	Lab ID:	0053	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	18.0	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-54 M S RM#204	Collected:		9/29/2016	Lab ID:	0054	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.37	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-55 M S REST RM	Collected:		9/29/2016	Lab ID:	0055	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.9	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-56 M S BOYS RM L	Collected:		9/29/2016	Lab ID:	0056	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.63	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description		OES-57 M S BOYS RM LC	Collected:		9/29/2016	Lab ID:		0057
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.36	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-58 M S BOYS RM RC	Collected:		9/29/2016	Lab ID:		0058
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.35	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-59 M S BOYS RM R	Collected:		9/29/2016	Lab ID:		0059
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.00	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-60 M F RM#205	Collected:		9/29/2016	Lab ID:		0060
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.72	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-61 M S RM#205	Collected:		9/29/2016	Lab ID:		0061
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.04	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-62 M S RM#207 NURSES OFFICE	Collected:		9/29/2016	Lab ID:		0062
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	30.8	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-63 M S RM#213	Collected:		9/29/2016	Lab ID:		0063
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.38	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description		OES-64 M S RM#216	Collected:		9/29/2016	Lab ID:		0064
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	52.2	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-65 M S RM#214	Collected:		9/29/2016	Lab ID:		0065
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.21	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-66 M F RM#219	Collected:		9/29/2016	Lab ID:		0066
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-67 M S RM#219	Collected:		9/29/2016	Lab ID:		0067
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-68 M F RM#220	Collected:		9/29/2016	Lab ID:		0068
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-69 M S RM#220	Collected:		9/29/2016	Lab ID:		0069
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-70 M F RM#221	Collected:		9/29/2016	Lab ID:		0070
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description		OES-71 M S RM#221	Collected:		9/29/2016	Lab ID:	0071	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-72 M S RM#222	Collected:		9/29/2016	Lab ID:	0072	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-73 M S WOMENS RM	Collected:		9/29/2016	Lab ID:	0073	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.50	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-74 M S CAFETERIA BATHROOM	Collected:		9/29/2016	Lab ID:	0074	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-75 M S KITCHEN HAND SINK	Collected:		9/29/2016	Lab ID:	0075	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	152	5.00	µg/L	10/3/2016	LY	10/4/2016	KB
Client Sample Description		OES-76 M S KITCHEN WAS SINK L	Collected:		9/29/2016	Lab ID:	0076	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.3	1.00	µg/L	10/2/2016	JS	10/3/2016	EG
Client Sample Description		OES-77 M S KITCHEN WAS SINK C	Collected:		9/29/2016	Lab ID:	0077	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	8.05	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description OES-78
M S KITCHEN WAS SINK R
Collected: 9/29/2016 **Lab ID:** 0078

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.28	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-79
M S KITCHEN BATHROOM
Collected: 9/29/2016 **Lab ID:** 0079

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	12.2	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-80
M S GYM OFFICE BATHROOM
Collected: 9/29/2016 **Lab ID:** 0080

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	11.3	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-81
2 S BATHRM BTWN RM#301 & #302
Collected: 9/29/2016 **Lab ID:** 0081

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.48	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-82
2 F RM#301
Collected: 9/29/2016 **Lab ID:** 0082

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-83
2 S RM#301
Collected: 9/29/2016 **Lab ID:** 0083

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-84
2 F RM#302
Collected: 9/29/2016 **Lab ID:** 0084

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011606397

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 09/30/16 8:30 AM

Project: Peekskill Schools Lead Testing / 2041420.027.00 / Oakside Elementary School

Analytical Results

Client Sample Description OES-85
2 S RM#302 **Collected:** 9/29/2016 **Lab ID:** 0085

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-86
2 F RM#303 **Collected:** 9/29/2016 **Lab ID:** 0086

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-87
2 S RM#303 **Collected:** 9/29/2016 **Lab ID:** 0087

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-88
2 S RM#304 **Collected:** 9/29/2016 **Lab ID:** 0088

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Client Sample Description OES-89
M HB EXT COURTYARD **Collected:** 9/29/2016 **Lab ID:** 0089

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.32	1.00	µg/L	10/2/2016	JS	10/3/2016	EG

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)