



EMSL Analytical, Inc.

200 Route 130 North, Cinnaminson, NJ 08077

Phone: (856) 303-2500 Fax: (856) 858-4571 Email: EnvChemistry2@emsl.com

Attn:

**Joseph Sbarra
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005**

10/27/2016

Phone: (212) 612-7900

Fax:

The following analytical report covers the analysis performed on samples submitted to EMSL Analytical, Inc. on 10/21/2016. The results are tabulated on the attached data pages for the following client designated project:

Peekskill Schools Lead Testing / 2041420.037.00

The reference number for these samples is EMSL Order #011607002. Please use this reference when calling about these samples. If you have any questions, please do not hesitate to contact me at (856) 303-2500.

Approved By:

Phillip Worby, Chemistry Laboratory Manager



The test results contained within this report meet the requirements of NELAP and/or the specific certification program that is applicable, unless otherwise noted.

NELAP Certifications: NJ 03036, NY 10872, PA 68-00367

The samples associated with this report were received in good condition unless otherwise noted. This report relates only to those items tested as received by the laboratory. The QC data associated with the sample results meet the recovery and precision requirements established by the NELAP, unless specifically indicated. All results for soil samples are reported on a dry weight basis, unless otherwise noted. This report may not be reproduced except in full and without written approval by EMSL Analytical, Inc.

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description PHS-01
LWR-S-L-ROOM 301
Collected: 10/20/2016 **Lab ID:** 0001

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.87	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-02
LWR-S-C-ROOM 301
Collected: 10/20/2016 **Lab ID:** 0002

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.22	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-03
LWR-S-R-ROOM 301
Collected: 10/20/2016 **Lab ID:** 0003

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.25	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-04
LWR-S-R-ROOM 301A
Collected: 10/20/2016 **Lab ID:** 0004

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	17.8	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-05
LWR-S-L-ROOM 300 LEFT WALL
Collected: 10/20/2016 **Lab ID:** 0005

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10600	125	µg/L	10/24/2016	LY	10/24/2016	JS

Client Sample Description PHS-06
LWR-S-R-ROOM 300 LEFT WALL
Collected: 10/20/2016 **Lab ID:** 0006

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.18	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-07
LWR-S-#1 ROOM 300 HANDWASH
Collected: 10/20/2016 **Lab ID:** 0007

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.1	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description PHS-08
 LWR-S-#2 ROOM 300 HANDWASH
Collected: 10/20/2016 **Lab ID:** 0008

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.58	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-09
 LWR-S-#3 ROOM 300 HANDWASH
Collected: 10/20/2016 **Lab ID:** 0009

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.19	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-10
 LWR-S-#4 ROOM 300 HANDWASH
Collected: 10/20/2016 **Lab ID:** 0010

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.58	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-11
 LWR-S-ROOM 300 (FORMER DARK ROOM)
Collected: 10/20/2016 **Lab ID:** 0011

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.40	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-12
 INT-S-ROOM 241C
Collected: 10/20/2016 **Lab ID:** 0012

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.61	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-13
 INT-S-ROOM 237B
Collected: 10/20/2016 **Lab ID:** 0013

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.1	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-14
 INT-S-L-R MENS BATH RM BY RM 237
Collected: 10/20/2016 **Lab ID:** 0014

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.86	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description PHS-15
 INT-S-MENS BATH RM BY RM 237
Collected: 10/20/2016 **Lab ID:** 0015

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.75	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-16
 INT-S-MENS FACULTY BTH RM BY RM 222
Collected: 10/20/2016 **Lab ID:** 0016

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.63	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-17
 INT-L W BATH RM
Collected: 10/20/2016 **Lab ID:** 0017

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	2.41	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-18
 INT-S-R WOMENS
Collected: 10/20/2016 **Lab ID:** 0018

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.34	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-19
 INT-S-WOMENS FACULTY
Collected: 10/20/2016 **Lab ID:** 0019

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.03	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-20
 INT-S-RM 210
Collected: 10/20/2016 **Lab ID:** 0020

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.64	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-21
 INT-S-RM 203
Collected: 10/20/2016 **Lab ID:** 0021

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.85	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description		PHS-23 S-RM 203 DRIPPING			Collected:	10/20/2016	Lab ID:	0023	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	3.21	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-24 INT-S-BATH RM BY RM 203			Collected:	10/20/2016	Lab ID:	0024	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-25 MAIN-S-MENS BATHROOM			Collected:	10/20/2016	Lab ID:	0025	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	7.20	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-26 MAIN-S-M. FACULTY BATH BY RM 112			Collected:	10/20/2016	Lab ID:	0026	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	2.39	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-27 MAIN-S-PRINCP. BATH RM			Collected:	10/20/2016	Lab ID:	0027	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	10.1	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-28 MAIN-S-MAIN OFFICE KITCHENETTE			Collected:	10/20/2016	Lab ID:	0028	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	2.85	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-29 MAIN-S-LIBRARY OFFICE			Collected:	10/20/2016	Lab ID:	0029	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	6.36	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description PHS-30 MAIN-S-TEACHERS DESK RM 116		Collected:	10/20/2016	Lab ID:	0030			
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	65.7	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description PHS-31 MAIN-S-L-R RM 116		Collected:	10/20/2016	Lab ID:	0031			
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.41	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description PHS-32 MAIN-S-L-R RM 116		Collected:	10/20/2016	Lab ID:	0032			
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	75.1	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description PHS-33 MAIN-S-L-R RM 116		Collected:	10/20/2016	Lab ID:	0033			
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.80	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description PHS-34 MAIN-S-HEALTH OFFICE BATHROOM		Collected:	10/20/2016	Lab ID:	0034			
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.72	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description PHS-35 MAIN-S-HEALTH OFFICE		Collected:	10/20/2016	Lab ID:	0035			
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	9.90	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description PHS-36 MAIN-S-G. LOCKER RM L-R		Collected:	10/20/2016	Lab ID:	0036			
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.25	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
Fax:
Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description PHS-37
MAIN-S-G. LOCKER RM
Collected: 10/20/2016 **Lab ID:** 0037

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.60	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description **PHS-38**
MAIN-S-G. LOCKER RM COACH OFFICE
Collected: 10/20/2016 **Lab ID:** 0038

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.4	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-39
MAIN-ICE MACHINE GYM OFFICE
Collected: 10/20/2016 **Lab ID:** 0039

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-40
MAIN-S-B. LOCKER RM L-R
Collected: 10/20/2016 **Lab ID:** 0040

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.46	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-41
MAIN-S-B. LOCKER RM
Collected: 10/20/2016 **Lab ID:** 0041

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.27	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-42
MAIN-S-B. LOCKER COACH OFFICE
Collected: 10/20/2016 **Lab ID:** 0042

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	4.79	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-43
MAIN-S-W. BATH RM
Collected: 10/20/2016 **Lab ID:** 0043

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	6.70	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
 Fax:
 Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description		PHS-44 MAIN-S-W. FACULTY BATH RM			Collected:	10/20/2016	Lab ID:	0044	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	1.64	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-45 MAIN-S-RM 109 TEACHER DESK			Collected:	10/20/2016	Lab ID:	0045	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	34.7	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-46 MAIN-S-RM 109 L-R			Collected:	10/20/2016	Lab ID:	0046	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	8.35	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-47 MAIN-S-RM 109 L-R			Collected:	10/20/2016	Lab ID:	0047	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	22.3	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-48 MAIN-S-RM 109 L-R			Collected:	10/20/2016	Lab ID:	0048	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	9.62	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-49 MAIN-S-RM 109 L-R			Collected:	10/20/2016	Lab ID:	0049	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	7.23	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-50 MAIN-S-RM 108 TEACHER DESK			Collected:	10/20/2016	Lab ID:	0050	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	94.0	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description		PHS-51 MAIN-S-RM 108 L-R			Collected:	10/20/2016	Lab ID:	0051	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	10.3	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-52 MAIN-S-RM 108 L-R			Collected:	10/20/2016	Lab ID:	0052	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	341	5.00	µg/L	10/24/2016	LY	10/24/2016	JS	
Client Sample Description		PHS-53 MAIN-S-RM 108 L-R			Collected:	10/20/2016	Lab ID:	0053	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	47.9	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-54 MAIN-S-RM 108 L-R			Collected:	10/20/2016	Lab ID:	0054	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	10.7	1.00	µg/L	10/22/2016	KB	10/23/2016	EG	
Client Sample Description		PHS-55 MAIN-S-RM 106 L-R			Collected:	10/20/2016	Lab ID:	0055	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	21.2	1.00	µg/L	10/22/2016	KB	10/23/2016	EG	
Client Sample Description		PHS-56 MAIN-S-RM 106 L-R			Collected:	10/20/2016	Lab ID:	0056	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	18.4	1.00	µg/L	10/22/2016	KB	10/23/2016	EG	
Client Sample Description		PHS-57 MAIN-S-RM 106 L-R			Collected:	10/20/2016	Lab ID:	0057	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	30.7	1.00	µg/L	10/22/2016	KB	10/23/2016	EG	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
Fax:
Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description PHS-58
MAIN-S-RM 106 L-R
Collected: 10/20/2016 **Lab ID:** 0058

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	29.9	1.00	µg/L	10/22/2016	KB	10/23/2016	EG

Client Sample Description PHS-59
MAIN-S-RM 106 L-R
Collected: 10/20/2016 **Lab ID:** 0059

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	26.1	1.00	µg/L	10/22/2016	KB	10/23/2016	EG

Client Sample Description PHS-60
MAIN-S-RM 106 L-R
Collected: 10/20/2016 **Lab ID:** 0060

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	30.6	1.00	µg/L	10/22/2016	KB	10/23/2016	EG

Client Sample Description PHS-61
MAIN-S-RM 106 L-R
Collected: 10/20/2016 **Lab ID:** 0061

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.7	1.00	µg/L	10/22/2016	KB	10/23/2016	EG

Client Sample Description PHS-62
MAIN-S-RM 106 L-R
Collected: 10/20/2016 **Lab ID:** 0062

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	38.9	1.00	µg/L	10/22/2016	KB	10/23/2016	EG

Client Sample Description PHS-63
MAIN-S-RM 106 L-R
Collected: 10/20/2016 **Lab ID:** 0063

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.8	1.00	µg/L	10/22/2016	KB	10/23/2016	EG

Client Sample Description PHS-64
MAIN-S-RM 106 L-R
Collected: 10/20/2016 **Lab ID:** 0064

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	20.9	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
Fax:
Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description PHS-65
MAIN-S-RM 106 L-R **Collected:** 10/20/2016 **Lab ID:** 0065

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	44.7	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-66
MAIN-S-RM 106 L-R **Collected:** 10/20/2016 **Lab ID:** 0066

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	163	5.00	µg/L	10/22/2016	KB	10/25/2016	EG

Client Sample Description PHS-67
MAIN-S-RM 106 OFFICE **Collected:** 10/20/2016 **Lab ID:** 0067

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	14.1	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-68
MAIN-S-RM 104 L-R **Collected:** 10/20/2016 **Lab ID:** 0068

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	1.79	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-69
MAIN-S-RM 104 L-R **Collected:** 10/20/2016 **Lab ID:** 0069

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	275	5.00	µg/L	10/22/2016	KB	10/25/2016	EG

Client Sample Description PHS-70
MAIN-S-RM 104 L-R **Collected:** 10/20/2016 **Lab ID:** 0070

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	173	5.00	µg/L	10/22/2016	KB	10/25/2016	EG

Client Sample Description PHS-71
MAIN-S-RM 104 L-R **Collected:** 10/20/2016 **Lab ID:** 0071

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.3	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
Fax:
Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description		PHS-72 MAIN-S-RM 104 L-R	Collected:		10/20/2016	Lab ID:		0072
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	119	5.00	µg/L	10/22/2016	KB	10/25/2016	EG
Client Sample Description		PHS-73 MAIN-S-RM 104 L-R	Collected:		10/20/2016	Lab ID:		0073
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	25.9	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description		PHS-74 MAIN-S-RM 104 L-R	Collected:		10/20/2016	Lab ID:		0074
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	16.6	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description		PHS-75 MAIN-S-RM 104 L-R	Collected:		10/20/2016	Lab ID:		0075
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	15.2	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description		PHS-76 MAIN-S-RM 104 L-R	Collected:		10/20/2016	Lab ID:		0076
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.0	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description		PHS-77 MAIN-S-RM 104 L-R	Collected:		10/20/2016	Lab ID:		0077
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	21.7	1.00	µg/L	10/22/2016	KB	10/22/2016	EG
Client Sample Description		PHS-78 MAIN-S-RM 104 L-R	Collected:		10/20/2016	Lab ID:		0078
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	34.3	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
Fax:
Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description PHS-79
MAIN-S-RM 104 L-R **Collected:** 10/20/2016 **Lab ID:** 0079

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	35.0	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-80
MAIN-S-RM 104 L-R **Collected:** 10/20/2016 **Lab ID:** 0080

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	99.6	5.00	µg/L	10/22/2016	KB	10/25/2016	EG

Client Sample Description PHS-81
MAIN-S-RM 107 **Collected:** 10/20/2016 **Lab ID:** 0081

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	147	5.00	µg/L	10/22/2016	KB	10/25/2016	EG

Client Sample Description PHS-82
MAIN-S-RM 103 TEACHER DESK **Collected:** 10/20/2016 **Lab ID:** 0082

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	19.4	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-83
MAIN-S-RM 103 L-R **Collected:** 10/20/2016 **Lab ID:** 0083

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.1	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-84
MAIN-S-RM 103 **Collected:** 10/20/2016 **Lab ID:** 0084

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	119	5.00	µg/L	10/22/2016	KB	10/25/2016	EG

Client Sample Description PHS-85
MAIN-S-RM 103 **Collected:** 10/20/2016 **Lab ID:** 0085

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	26.4	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
Fax:
Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description PHS-86
MAIN-S-RM 103
Collected: 10/20/2016 **Lab ID:** 0086

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	24.2	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-87
MAIN-S-RM 102 TEACHER DESK
Collected: 10/20/2016 **Lab ID:** 0087

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	10.4	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-88
MAIN-S-RM 102 L-R
Collected: 10/20/2016 **Lab ID:** 0088

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	81.3	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-89
MAIN-S-RM 102
Collected: 10/20/2016 **Lab ID:** 0089

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	3.57	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-90
MAIN-S-RM 102
Collected: 10/20/2016 **Lab ID:** 0090

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	13.5	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-91
MAIN-S-RM 101 TEACHER DESK
Collected: 10/20/2016 **Lab ID:** 0091

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	7.38	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

Client Sample Description PHS-92
MAIN-S-RM 101 L-R
Collected: 10/20/2016 **Lab ID:** 0092

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	18.2	1.00	µg/L	10/22/2016	KB	10/22/2016	EG

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description		PHS-93 MAIN-S-RM 101		Collected:		10/20/2016	Lab ID:		0093
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	6.22	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-94 MAIN-S-RM 101		Collected:		10/20/2016	Lab ID:		0094
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	44.4	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-95 MAIN-S-RM 100 TEACHER DESK		Collected:		10/20/2016	Lab ID:		0095
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	8.76	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-96 MAIN-S-RM 100 L-R		Collected:		10/20/2016	Lab ID:		0096
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	15.4	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-97 MAIN-S-RM 100		Collected:		10/20/2016	Lab ID:		0097
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	16.2	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-98 MAIN-S-RM 100		Collected:		10/20/2016	Lab ID:		0098
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	52.5	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-100 MAIN-BOTTLE FILTER CAFETERIA		Collected:		10/20/2016	Lab ID:		0100
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900
Fax:
Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description		PHS-101 MAIN-HIWASH KITCHEN			Collected:	10/20/2016	Lab ID:	0101	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-102 MAIN-ICE MACH. KITCHEN			Collected:	10/20/2016	Lab ID:	0102	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-103 MAIN-PREP. S KITCHEN			Collected:	10/20/2016	Lab ID:	0103	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	114	2.00	µg/L	10/24/2016	LY	10/24/2016	JS	
Client Sample Description		PHS-104 MAIN-PREP. S KITCHEN			Collected:	10/20/2016	Lab ID:	0104	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-105 MAIN-S-KITCHEN BATHROOM			Collected:	10/20/2016	Lab ID:	0105	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	3.94	1.00	µg/L	10/22/2016	KB	10/22/2016	EG	
Client Sample Description		PHS-106 MAIN-WASH S KITCHEN			Collected:	10/20/2016	Lab ID:	0106	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/24/2016	JS	
Client Sample Description		PHS-107 MAIN-WASH S KITCHEN			Collected:	10/20/2016	Lab ID:	0107	
Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst	
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/24/2016	JS	

**EMSL Analytical, Inc.**

200 Route 130 North, Cinnaminson, NJ 08077

Phone/Fax: (856) 303-2500 / (856) 858-4571

<http://www.EMSL.com>EnvChemistry2@emsl.com

EMSL Order: 011607002

CustomerID: LBAP78

CustomerPO:

ProjectID:

Attn: **Joseph Sbarra**
Louis Berger U.S., Inc
48 Wall St.
New York, NY 10005

Phone: (212) 612-7900

Fax:

Received: 10/21/16 7:10 AM

Project: Peekskill Schools Lead Testing / 2041420.037.00

Analytical Results

Client Sample Description PHS-108
MAIN-PREP S KITCHEN

Collected: 10/20/2016 **Lab ID:** 0108

Method	Parameter	Result	RL	Units	Prep Date	Analyst	Analysis Date	Analyst
200.8	Lead	ND	1.00	µg/L	10/22/2016	KB	10/24/2016	JS

Definitions:

ND - indicates that the analyte was not detected at the reporting limit

RL - Reporting Limit (Analytical)